

GAQFC.EX6264 Clean Agent Extinguishing System Units

[Page Bottom](#)

Clean Agent Extinguishing System Units

[See General Information for Clean Agent Extinguishing System Units](#)

SAFETY HI-TECH SRL
VIA CAVOUR 96
67051 AVEZZANO, AQ ITALY

EX6264

ENGINEERED UNITS

Models SH70025410, SH70025409, SH70025408, SH70025407, SH70025406, SH70025412, SH70025405, SH70025404, SH70025403, NAF S 125 Clean Agent Extinguishing System Units, stored pressure type, having nominal charging capacities of 5, 13, 26, 40, 67, 67.5, 75, 100 and 120 L of NAF S 125 Clean Agent, respectively. The units are super pressurized to 42 bar with operating temperatures of -18 C to +50 C. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

These systems are intended to be designed and installed in accordance with the Listee's installation, maintenance and user's manual, P/N SHIM0104 Rev. 00, dated January, 2004; and Design manual P/N SHDM0103 Rev. 01, dated April, 2004; and Addendum P/N SHAD0105 Rev 01, dated March 2004. Copies are available from the Listee. Design program is accessed through Safety Hi-Tech NAF S 125 Flowcalc, Version SHT3.71 floppy disc or CD and the flow program User's Manual P/N SHFlowcalc-125, dated April, 2004.

Models SH70027410, SH70027409, SH70027408, SH70027407, SH70027406, SH70027412, SH70027405, SH70027404, SH70027403 (HFC-227ea with limonene additive, 0.15% by weight) Clean Agent Extinguishing Systems Units, stored pressure types, having nominal capacities of 5, 13, 26, 40, 67, 67.5, 75, 100 and 120L. The units are super pressurized to 42 bar with operating temperatures of 0 °C to + 50 °C. These units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure. These systems are intended to be designed and installed in accordance with the NAF S 227® Engineered Systems Design Manual (SHDMS227EN); Installation, Maintenance and User Manual for NAF S 227® Fire Extinguishing Systems (SHIMS227EN). The design program NAF S 227® Flow Calculation Software Version SHT 3.03 CD is accessed through Safety Hi-Tech, User's Manual (P/N SHFlowcalc-227).

Models SH70027413, SH70027414, SH70027415 (HFC-227ea with limonene additive, 0.15% by weight) Clean Agent Extinguishing System Units, stored pressure type, having nominal capacities of 142, 175 and 240 liters. These units are super pressurized to 25 bar with operating temperature of 0 °C to + 50 °C. These units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure. These systems are intended to be designed and installed in accordance with the NAF S 227® Engineered Systems Design Manual (SHDMS227EN); Installation, Maintenance and User Manual for NAF S 227® Fire Extinguishing Systems (SHIMS227EN). The design program NAF S 227® Flow Calculation Software Version SHT 3.03 CD is accessed through Safety Hi-Tech, User's Manual (P/N SHFlowcalc-227).

[Last Updated](#) on 2010-10-18

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories of Canada Inc.](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

