



VDXY.EX4224 Branch-line Testers

[Page Bottom](#)

Branch-line Testers

[See General Information for Branch-line Testers](#)

FIRE-END & CROKER CORP

EX4224

7 WESTCHESTER PLAZA
ELMSFORD, NY 10523 USA

Branch line tester, Model 8080 for use at the end sprinkler of system branch lines as a means of testing for internal obstruction or stoppage of sprinkler piping. For sprinkler systems using standard orifice or small sprinkler.

For maximum working pressure of 175 psig.

[Last Updated](#) on 2004-01-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".