



VVHV.EX4959 Roof Manifolds

[Page Bottom](#)

Roof Manifolds

[See General Information for Roof Manifolds](#)

FIRE-END & CROKER CORP

EX4959

7 WESTCHESTER PLAZA
ELMSFORD, NY 10523 USA

Roof manifolds intended for a maximum rated pressure of 300 psig consisting of the following models:

Model	Size In.	Pattern
6806	6x3x3x3	Vertical
6807	6x3x3x3x3	Vertical
6808	6x3x3x3x3x3x3	Vertical
6870	2-1/2x2-1/2x2-1/2x4	Horizontal-90°
6871	2-1/2x2-1/2x2-1/2x6	Horizontal-90°
6890	2-1/2x2-1/2x4	Vertical
6892	2-1/2x2-1/2x2-1/2x4	Vertical
6893	2-1/2x2-1/2x2-1/2x6	Vertical

Last Updated on 1999-11-16

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".