



ONLINE CERTIFICATIONS DIRECTORY

**VUFZ.EX1394
Nozzles, Spray Hose, Portable**

See General Information for Nozzles, Spray Hose, Portable

ELKHART BRASS MFG CO INC
1302 W BEARDSLEY AVE
PO BOX 1127
ELKHART, IN 46515 USA

EX1394

Adjustable Nozzles – For Classes A, B, and C fires. For use with rubber-lined or unlined fire hose. A suffix letter “B” may be used to denote a rubber bumper.

Model No.	Size In.	Nozzle Pressure psi	Discharge GPM Wide Open
L-205-EB60*	1-1/2	100	65
L-205-EB95*	1-1/2	100	102
L-205-EB125*	1-1/2	100	135
NSL*	1-1/2	100	92

Model No.	Size In.	Nozzle Pressure psi	Discharge GPM Wide Open
205-B(170)+	2-1/2	100	171
D205-B(170)+	2-1/2	100	171
205-B(250)+	2-1/2	100	275
D205-B(250)+	2-1/2	100	275
L-205-B40+	1-1/2	100	39
L-205-B60+	1-1/2	100	61
L-205-B95+	1-1/2	100	100
L-205-B125+	1-1/2	100	135
L-206T+	1-1/2	100	120
S-205B-12GPM+	1	100	12
S-205-B-23GPM+	1	100	28

Note: Adjustable Nozzles – For Classes A and B fires only. For use with rubber-lined or unlined fire hose. A suffix letter “B” may be used to denote a rubber bumper. The Models S-205-B, 205B(170), D205-B(170), 205B(250) and D205-B(250) are for use with rubber-lined fire hose only.

+Use of solid stream from nozzle around live electrical apparatus and circuits may involve serious accident hazard, and these nozzles, therefore, are not recommended for use in Class C fires.

*Use of these nozzles not likely to prove hazardous when held at distance in excess of 10 ft from live electrical apparatus and circuits involving voltages not in excess of 250,000.

Last Updated on 1996-10-31



ONLINE CERTIFICATIONS DIRECTORY

VUFZ.EX1394 – CONTINUED

**VUFZ.EX1394
Nozzles, Spray Hose, Portable**

[See General Information for Branch Line Testers](#)

ELKHART BRASS MFG CO INC
1302 W BEARDSLEY AVE
PO BOX 1127
ELKHART, IN 46515 USA

EX1394

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2007 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2007 Underwriters Laboratories Inc.®"

September, 2007